




COMPLIANCE TESTED by berkeley analytical

VOC Emission Test Certificate

Product Name: Titebond Original Wood Glue - 2213

Product Sample Information		Certificate Information	
Company:	Franklin International	Certificate No:	240111-03
Company Website:	www.franklininternational.com	Certified By:	 Raja S. Tannous, Laboratory Director
Product Type:	Wood Glue – Cabinets and Desks	Date:	January 11, 2024
Date Produced:	11/10/2023		

Reference Standard: California Department of Public Health CDPH/EHLB/Standard Method Version 1.2, 2017 (Emission testing method for CA Specification 01350)

Acceptance Criteria and Results Demonstrating Compliance of Product Sample to Referenced Standard:

Exposure Scenario ¹	Individual VOCs of Concern ²		Formaldehyde ³		TVOC ⁴
	Criterion	Compliant?	Criterion	Compliant?	Range
School Classroom	≤½ Chronic REL	YES	≤9.0 µg/m ³	YES	≤ 0.5 mg/m ³
Private Office	≤½ Chronic REL	YES	≤9.0 µg/m ³	YES	≤ 0.5 mg/m ³

Product Coverage⁵: 195 g/m² (see attached letter for use and loading)

1. Exposure scenarios & product quantities for classroom & office are defined in Tables 4-2 – 4-5 (CDPH Std. Mtd. V1.2-2017)
2. Maximum allowable concentrations of individual target VOCs are specified in Table 4-1 (*ibid.*)
3. Maximum allowable formaldehyde concentration is ≤9 µg/m³, effective Jan 1, 2012; previous limit was ≤16.5 µg/m³ (*ibid.*)
4. Informative only; predicted TVOC Range in three categories, i.e., ≤0.5 mg/m³, >0.5 – 4.9 mg/m³, and ≥5.0 mg/m³
5. Informative and applicable only to tests of wet-applied products; grams of sample applied per square meter of substrate

Standards & Codes Recognizing CDPH Standard Method V1.2 (partial list)

- USGBC LEED Version 4/4.1, BD&C, ID&C, Residential BD&C Multifamily
- The WELL Building Standard, WELL v2, Feature X06
- ANSI/GBI 01-2019 Green Globes Assessment Protocol

Narrative: Franklin International selected a sample representative of its Titebond Original Wood Glue - 2213, an aliphatic resin emulsion adhesive for desks and cabinets product and submitted it on 12/19/2023 for testing. Berkeley Analytical measured and evaluated the emissions of VOCs from this sample following CDPH/EHLB/Standard Method V1.2-2017. The results of the test are presented in Berkeley Analytical report, 338-063-01A-Jan1124.

Berkeley Analytical is an independent, third-party laboratory specializing in the analysis of organic chemicals emitted by and contained in building products, finishes, furniture, and consumer products. We are an ISO/IEC 17025 accredited laboratory (IAS, [TL-383](#)); all standards used in performing this test are in Berkeley Analytical's scope of accreditation.

DISCLAIMER: THIS CERTIFICATE OF COMPLIANCE AFFIRMS THAT: 1) A SAMPLE OF THE LISTED PRODUCT WAS TESTED ACCORDING TO THE REFERENCED STANDARD; 2) THE MEASURED VOC EMISSIONS FROM THE SAMPLE WERE EVALUATED FOR THE DEFINED EXPOSURE SCENARIO(S); AND 3) THE RESULTS MEET THE ACCEPTANCE CRITERIA OF THE REFERENCED STANDARD(S). BERKELEY ANALYTICAL IS NOT RESPONSIBLE FOR ANY CLAIMS REGARDING A PRODUCT OR PRODUCTS ENTERED INTO COMMERCE THAT MAY BE BASED ON THIS TEST. BERKELEY ANALYTICAL PROVIDES THIS CERTIFICATE OF COMPLIANCE "AS IS" WITHOUT WARRANTY OF ANY KIND, EITHER EXPRESSED OR IMPLIED, INCLUDING BUT NOT LIMITED TO, THE IMPLIED WARRANTIES OF MERCHANTABILITY OR FITNESS FOR ANY PURPOSE.

Franklin International

12/14/2023

VOC Emission Testing; CDPH Standard Method V1.2; non-full spread adhesive application calculations

Below are the rationale and the calculations for a quantity of Franklin International's Titebond Original Wood Glue that would be used in the standard school classroom and the standard private office defined in CDPH Standard Method V1.2.

Assumption: Adhesive will be used for furniture, cabinets, desks, etc. in a classroom of 960 sq. ft. (40 x 24 size room) or an office of 120 sq. ft. (12 x 10 size office.)


CLASSROOM

Classroom will have 27 seating for 27 pupils, so there are 27 desks taking up 250 sq. ft. plus 64 linear feet of cabinets for storage = 0.54 gallons (69 oz.) of adhesive to laminate desks and 1 gallon of adhesive to laminate cabinets.

OFFICE

Office will have desk, chairs, and cabinets = 0.5 gallon (64 oz.) of glue for assembling furniture

Sincerely,



Ben Ward
Product Compliance Specialist
Franklin International